

# SAFETY NOTICE



## Issue:

Kidde has discovered that in a small number of cases, black plastic Zytel® nylon valve disposable fire extinguishers may not fully discharge as designed when the lever is pressed and released multiple times. The cause is an out-of-specification valve component.

## Description of Products:

Kidde ABC- or BC-rated extinguishers manufactured between July 23, 2013 and October 15, 2014. The affected fire extinguishers are 5BC (white or red), 10BC (red), 1A10BC (white or red), and 2A10BC (blanc). The Kidde logo and serial number are on the nameplate for each unit. A 10-digit date code is ink-jet printed onto each extinguisher near the bottom of the cylinder.

*We are looking for units with these five digits in the date code:*


*2013: XXXX20413X through XXXX36513X*

*2014: XXXX00114X through XXXX28814X*

Example: Date code is 0101273145.

The digits 27314 signify it was manufactured on the 273<sup>rd</sup> day of 2014, or September 30, 2014.

This unit would be among those affected.



**Remedy:** Replace unit.

Please call Kidde Canada's Recall Center at 1-844-833-6394 between 8 a.m. – 5 p.m. EST Monday through Friday, except holidays, or visit our website at [www.kiddecanada.com](http://www.kiddecanada.com).

Post until at least 120 days from recall announcement.  
In cooperation with Health Canada.